GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T :4845,4866,4885 & 4900/ Lab /122/ 2022 - 23 Dated:- 14/06/2022.

Laboratory : Bicholim - Goa.
Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work: "Construction of Tail Minor DO's W.C and F.C's of B-4 distributory and DWC 19L off taking At Ch. 18.005 Km. of R.B.M.C of T.I.P at village Dhargal in Pernem Taluka.

Ref. to Requisition No.: SDIV/WDVII/WRD/F.10/22-23/23 Dt.:-07/ 06/ 2022

Oty. Recived.: 04 Sets of cube Date of Receipt:- 08/ 06 / 2022. Tested on: 08,09,10 & 11/06/2022 as per due dates. Ref to CPWD: 2009, Vol. I Sample: Cube Mix 1:2:4 & 1:1.5:3 O.S No.: 8810,8831,8851 & 8868/SS Lab. Sample No.: 4832 to 4835 Tested By: Mrs. S. B. Naik Shirodkar. J.E.

REPORT PAGE 01 OF 01

| SR. NO | DISCRIPTION OF SAMPLE | TESTED FOR | RESULTS | | Max./Min.Value permissable | % above or below | REMARK |
|-----------|--|----------------------|---------|--------------------|----------------------------|------------------|-----------------------------|
| 1 | Cement concrete cube of mix 1:2:4 , cast on 11/05/2022. For P.C.C. | 28 th day | 219.73 | Kg/Cm ² | 210.00 Kg/cm ² | 6.07 | Oty represents - 15.00 Cum. |
| | | compressive | 244.65 | Kg/Cm ² | | | |
| | | strength | 203.87 | Kg/Cm ² | | | |
| | | Average | 222.75 | Kg/Cm ² | | | |
| 2 | Cement concrete cube of mix 1:1.5:3 , cast on 12/05/2022. For Pedestal. | 28 th day | 276.36 | Kg/Cm ² | 265.00 Kg/cm ² | 1.44 | Oty represents - 12.00 Cum. |
| | | compressive | 258.24 | Kg/Cm ² | | | |
| | | strength | 271.83 | Kg/Cm ² | | | |
| | | Average | 268.81 | Kg/Cm ² | | | |
| 3 | Cement concrete cube of mix 1:1.5:3 , cast on 13/05/2022. For Chambers. | 28 th day | 271.83 | Kg/Cm ² | 265.00 Kg/cm ² | 2.29 | Oty represents - 12.00 Cum. |
| | | compressive | 283.16 | Kg/Cm ² | | | |
| | | strength | 258.24 | Kg/Cm ² | | | |
| | | Average | 271.08 | Kg/Cm ² | | | |
| 4 | Cement concrete cube of mix 1:1.5:3 , cast on 14/05/2022. For Pedestal. | 28 th day | 283.16 | Kg/Cm ² | 265.00 Kg/cm ² | 5.43 | Oty represents - 14.00 Cum. |
| | | compressive | 292.22 | Kg/Cm ² | | | |
| | | strength | 262.77 | Kg/Cm ² | | | |
| | | Average | 279.38 | Kg/Cm ² | | | |

Copy to: 1. The Assistant Engineer , SDIV , WD VII, WRD, Dhargal, Pernem - Goa.

- 2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to The Executive Engineer , WD VII ,WRD, Dhargal, Pernem Goa.
- 4. QC Lab File. 5. Bill File.