

GOVERNMENT OF GOA
QUALITY CONTROL LABORATORY
WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T :4371 & 4372/ Lab /66/ 2022 - 23 Dated:- 10/ 05 /2022.

Laboratory : Bicholim - Goa.
Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work :Augmentation of Right Bank Main Canal of T.I.P at ch 12.950 km from Kalna river to secure uninterrupted raw water supply for drinking, agricultural and industrial purpose during the annual canal maintenance period of TIP dam and its appurtenances”.

Ref. to Requisition No.: SDIV/WDVII/WRD/F.19/2022-2023/05 Dt.:-29/ 04/ 2022

Qty. Received. : 2 Sets of cube Date of Receipt:- 09/ 05 / 2022. Tested on: 09/05/2022 as per due dates. Ref to CPWD :2009, Vol. I

Sample: Cube Mix PCC **1:2:4** O.S No. :0660 & 0661/R.K Lab. Sample No.: 4353 & 4354 Tested By: Mrs. R. R. Kadam A.E.

REPORT PAGE 01 OF 01

SR. NO	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Cement concrete cube of mix 1:2:4 , cast on 11/04/2022. For PCC Foundation of Forebay, reataining walls.	28 th day compressive strenath	215.20	Kg/Cm ²	210.00 Kg/cm ²	2.84	Qty represents - 6.00 Cum for two sets of cubes.
			222.00	Kg/Cm ²			
			210.67	Kg/Cm ²			
		Average	215.95	Kg/Cm²			
2	Cement concrete cube of mix 1:2:4 , cast on 11/04/2022. For PCC Foundation of Forebay, reataining walls.	28 th day compressive strenath	210.67	Kg/Cm ²	210.00 Kg/cm ²	2.12	----- do -----
			215.20	Kg/Cm ²			
			217.47	Kg/Cm ²			
		Average	214.44	Kg/Cm²			

Copy to: 1. The Assistant Engineer , SDIV , WD VII, WRD,Dhargal, Pednem - Goa.

2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

3. Copy submitted to The Executive Engineer , WD VII ,WRD, Dhargal, Pednem - Goa.

4. QC Lab File. 5. Bill File.

Assistant Engineer