

GOVERNMENT OF GOA
QUALITY CONTROL LABORATORY
WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T :3498/ Lab /07 / 2022 - 23 Dated:- 01 /04/ 2022.

Laboratory : Bicholim - Goa.

Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work : Construction of protection wall for Nalla from Shri Amrut Pednekar House to Kishore Patil House at Chinch – Bhatwadi, Mayem in Sy. No. 185 of Bicholim Taluka.

Ref. to Requisition No.: WRD/SDV/QC/WDVIII/F.3-9/2021-22/338(QC Programme) Dt.:-18/ 02/ 2022

Qty. Received. : 01 Set of cube Date of Receipt:- 18/ 02 / 2022. Tested on: 18/03/2022 as per due dates. Ref to CPWD :2009, Vol. I

Sample: Cube Mix PCC - 1:2:4 O.S No. :7958/SS Lab. Sample No.: 3045 Tested By: Mrs. S. B. Naik Shirodkar. J.E.

REPORT PAGE 01 OF 01

| SR. NO | DISCRIPTION OF SAMPLE | TESTED FOR | RESULTS | | Max./Min. Value permissible | % above or below | REMARK |
|--------|---|---|---------------|--------------------------|-----------------------------|------------------|--------|
| 1 | Cement concrete cube of mix 1:2:4, cast on 18/02/2022(Cubes were casted during site inspection by Q.C.Officials at site in the presence of Departmental Engineers and representative by agency M/s. Cherkala Constructions, Panditwada, Ponda Goa, civil contractor, Engineerings Services Pvt. Ltd.) | 28 th day compressive strength | 217.47 | Kg/Cm ² | 210.00 Kg/cm ² | 4.27 | ---- |
| | | | 206.14 | Kg/Cm ² | | | |
| | | | 233.32 | Kg/Cm ² | | | |
| | | Average | 218.98 | Kg/Cm² | | | |

Copy to: 1. The Assistant Engineer , SDI, WDV, WRD, Bicholim - Goa.

2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

3. Copy submitted to The Executive Engineer , WD VI ,WRD, Bicholim - Goa.

4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer