

GOVERNMENT OF GOA
QUALITY CONTROL LABORATORY
WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T :4215/ Lab /63 / 2022 - 23 Dated:- 04/05/ 2022.

Laboratory : Bicholim - Goa.

Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work : Improvement to existing nallah from Shri Sadanand Verekar house to Shri Anil Parulekar house and near Valankani Chapel at Dhon Wado in saligao Constituency.

Ref. to Requisition No.: WRD/SDV/QC/WDVIII/F.3-9/2022-23/340(QC Programme) Dt.:-26/ 04/ 2022

Qty. Recived. : 01 Set of cube Date of Receipt:- 26/ 04 / 2022. Tested on: 03/05/2022 as per due dates. Ref to CPWD :2009, Vol. I

Sample: Cube Mix PCC - **1:2:4** O.S No. :0503/R.K Lab. Sample No.: 4041 Tested By: Mrs. R. R. Kadam A.E.

REPORT PAGE 01 OF 01

SR. NO	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min. Value permissible	% above or below	REMARK
1	Cement concrete cube of mix PCC 1:2:4 , cast on 26/04/2022(Cubes were casted during site inspection by Q.C.Officials at site in the presence of Departmental Engineers and representative by agency M/s Bitcon Civil Contractors,Engineering Services Pvt. Ltd.)	07 th day compressive strength	167.63	Kg/Cm ²	140.00 Kg/cm ²	11.65	1. Quantity represents 6.30 Cum. 2. 28th day test due on 24/05/2022.
			156.30	Kg/Cm ²			
			144.98	Kg/Cm ²			
		Average	156.30	Kg/Cm²			

Copy to: 1. The Assistant Engineer , SDII , WDI, WRD, Mapusa - Goa.

2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

3. Copy submitted to The Executive Engineer , WDI ,WRD, Porvorim - Goa.

4. QC Lab File. 5. Bill File.

Assistant Engineer