

GOVERNMENT OF GOA
QUALITY CONTROL LABORATORY
WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T :-3817 & 4097/ Lab / 51/ 2022 - 23 Dated:- 28/ 04 / 2022.

Laboratory : Bicholim - Goa.
Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work : Construction of 12 Triple Bedroom Flats in Sector "H" Phase -II at Porvorim.

Ref. to Requisition No.: 1)GHB/EE(N)/15/ 2022 dated :-06/ 04/2022.

2)GHB/EE(N)/17/2022 dated:-06/04/2022.

Qty. Received. : 01 Set each Date of Receipt:- 07/04/2022 Tested on: - 05 & 26/04/2022 . Ref to CPWD :2009, Vol. I

Sample: Cube Mix **M-25** O.S No. :8014 & 8360/SS. Lab. Sample No.: 3770 & 3771. Tested By: Mrs. S.B. Naik Shirodkar. J.E.

REPORT PAGE 01 OF 01

SR.N O.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissible	% above or below	REMARK
1	Cement concrete cube of mix M-25 , cast on 29/03/2022. For fourth part flat slab of Phase II building.	07 th day compressive strength	237.85	Kg/Cm ²	210.00 Kg/cm ²	2.48	Quantity represented and exact location by set of cube for the work is not mentioned .
			208.40	Kg/Cm ²			
			199.34	Kg/Cm ²			
		Average	215.20	Kg/Cm²			
1	Cement concrete cube of mix M-25 , cast on 29/03/2022. For fourth part flat slab of Phase II building.	28 th day compressive strength	312.61	Kg/Cm ²	290.00 Kg/cm ²	4.41	----- do -----
			303.55	Kg/Cm ²			
			292.22	Kg/Cm ²			
		Average	302.79	Kg/Cm²			

Copy to: 1. The Assistant Engineer (N),Goa Housing Board , North Division , alto Betim ,Porvorim Bardez - Goa.

2. QC Lab File. 3. Bill File.

Junior Engineer

Assistant Engineer