### **GOVERNMENT OF GOA**

# QUALITY CONTROL LABORATORY

## WATER RESOURCES DEPARTMENT

Test Report No.: WRD/QC/F.6-2/Cube -T: 173,177 & 178 / Lab / 101 / 2020 - 2021 Dated: - 22 / 07/ 2020

Laboratory: Bicholim-Goa / Sub Division V (QC)/WRD/ Bicholim-Goa.

# Name of Work: - Improvement to Existing Bandhara at D/S of Vehicular bridge at Assonora. Regarding construction of side protection wall at RHS bank of Assonara.

Ref. to Requisition No.: F.36/SD III/WDVI/WRD/2020-21/ **42**Ref. to Requisition No.: F.36/SD III/WDVI/WRD/2020-21/ **43**Dated :- 19-06-2020

Dated :- 23-06-2020

Qty. Recived.: 01 + 02 Sets of cube Date of Receipt: -20 & 23/06/2020. Tested on:- 11, 18 & 19/07/2020 . Ref to CPWD: 2009, Vol. I

Sample: PCC 1:2:4 Mix O.S No.: 4063,4067 & 4068/SS. Lab. Sample No.: 9257,9265 & 9266 Tested By: - Mrs. S. B. Naik Shirodkar, J.E.

### **REPORT PAGE 01 OF 01**

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1 1	Cement concrete cube of mix <b>1:2:4,</b> cast on 13/06/2020. PCC for retaining wall foundation.	28 <sup>th</sup> day	240.12	Kg/Cm <sup>2</sup>	210.00 Kg/Cm <sup>2</sup> 1		Represents Qty. 19.00 Cum.
		compressive	258.24	Kg/Cm <sup>2</sup>		15.06	
		strength	226.53	Kg/Cm <sup>2</sup>		15.00	
		Average	241.63	Kg/Cm <sup>2</sup>			
2	Cement concrete cube of mix <b>1:2:4</b> , cast on 20/06/2020. PCC for retaining wall foundation and side wall.	28 <sup>th</sup> day	212.93	Kg/Cm <sup>2</sup>	210.00 Kg/Cm <sup>2</sup>	4.99	Represents Qty. 18.00 Cum.
		compressive strength	203.87	Kg/Cm <sup>2</sup>			
			244.65	Kg/Cm <sup>2</sup>			
		Average	220.49	Kg/Cm <sup>2</sup>			
1 7	Cement concrete cube of mix <b>1</b> : <b>2</b> : <b>4</b> , cast on 21/06/2020. PCC for retaining side wall.	28 <sup>th</sup> day	217.47	Kg/Cm <sup>2</sup>	210.00 Kg/Cm <sup>2</sup>	9.31	Represents Qty. 19.00 Cum.
		compressive strength	240.12	Kg/Cm <sup>2</sup>			
			231.06	Kg/Cm <sup>2</sup>			
		Average	229.55	Kg/Cm <sup>2</sup>			

- 1.Copy to: The Assistant Engineer SD III, WD VI, WRD, Mulgao Goa.
- 2. Copy submitted to:The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa. For kind Information.
- 3. Copy submitted to:The Executive Engineer, WD VI, WRD, Bicholim-Goa.
- 4. QC Lab File. 5. Bill File.