GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD/QC/F.6-2/Cube -T : 7206 To 7219 / Lab / **186** / 2019 - 20 Dated: 14 / 06 / 2019

Laboratory: Bicholim-Goa / Sub Division V (QC)/WRD/ Bicholim-Goa.

Name of Work: - Construction of Barrage and up gradation of Raw water pumping station at Ganjem on Mhadei River for Augmentation of Raw water for Opa water works Reg. Construction of Barrage, providing and laying 1000 mm dia. D.I. pipe Rising main and Break Pressure Tank at Ganjem in Sattari Taluka.

Ref. to Requisition No.: WRD/WDVI/SD I /F.W.215/2019-20/ 199 Dated :- 12-06-2019

Qty. Recived.: 14 Sets of cube Date of Receipt: - 13/06/2019. Tested on: -13/06/2019 Ref to CPWD: 2002, Vol. I

Sample: PCC 1:1.5:3 Mix O.S No.: 841/AF To 854/AF. Lab. Sample No.: 6102 To 6115. Tested By: - Mr. Anil R. Fadte, J.E.

REPORT PAGE 01 OF 02

SR.NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 16/05/2019, RCC for floor of Barage from 0-55 m.	28th day	294.48	Kg/Cm ²	265.00 Kg/Cm ²	17.96	Represents Qty. 20.00 Cum.
		compressive	312.61	Kg/Cm ²			
		strength	330.73	Kg/Cm ²			
		Average	312.61	Kg/Cm ²			
2	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 16/05/2019, RCC for floor of Barage from 0-55 m.	28th day	328.46	Kg/Cm ²	265.00 Kg/Cm ²	21.38	-do-
		compressive	323.93	Kg/Cm ²			
		strength	312.61	Kg/Cm ²			
		Average	321.67	Kg/Cm ²			
	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 16/05/2019, RCC for floor of Barage from 0-55 m.	28th day	303.55	Kg/Cm ²	265.00 Kg/Cm ²	20.24	-do-
3		compressive	326.20	Kg/Cm ²			
3		strength	326.20	Kg/Cm ²			
		Average	318.65	Kg/Cm ²			
4	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 16/05/2019, RCC for floor of Barage from 0-55 m.	28th day	323.93	Kg/Cm ²	265.00 Kg/Cm ²	20.81	-do-
		compressive	310.34	Kg/Cm ²			
-		strength	326.20	Kg/Cm ²			
		Average	320.16	Kg/Cm ²			
5	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 16/05/2019, RCC for floor of Barage from 0-55 m.	28th day	323.93	Kg/Cm ²	265.00 Kg/Cm ²	21.38	-do-
		compressive	312.61	Kg/Cm ²			
		strength	328.46	Kg/Cm ²			
		Average	321.67	Kg/Cm ²			
6	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 16/05/2019, RCC for floor of Barage from 0-55 m.	28th day	296.75	Kg/Cm ²	265.00 Kg/Cm ²	18.53	-do-
		compressive	314.87	Kg/Cm ²			
		strength	330.73	Kg/Cm ²			
		Average	314.12	Kg/Cm ²			

REPORT PAGE 02 OF 02

SR.NO.	DISCRIPTION OF SAMPLE	TESTED FOR	STED FOR RESULTS		Max./Min.Value permissable	% above or	REMARK
7	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 16/05/2019, RCC for floor of Barage from 0-55 m.	28th day	326.20	Kg/Cm ²	265.00 Kg/Cm ²	19.67	Represents Qty. 20.00 Cum.
		compressive	310.34	Kg/Cm ²			
		strength	314.87	Kg/Cm ²			
		Average	317.14	Kg/Cm ²			
8	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 16/05/2019, RCC for floor of Barage from 0-55 m.	28th day	323.93	Kg/Cm ²	265.00 Kg/Cm ²	20.81	-do-
		compressive	323.93	Kg/Cm ²			
		strength	312.61	Kg/Cm ²			
		Average	320.16	Kg/Cm ²			
	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 16/05/2019, RCC for floor of Barage from 0-55 m.	28th day	319.40	Kg/Cm ²	265.00 Kg/Cm ²	19.39	-do-
9		compressive	323.93	Kg/Cm ²			
_		strength	305.81	Kg/Cm ²			
		Average	316.38	Kg/Cm ²			
	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 16/05/2019, RCC for floor of Barage from 0-55 m.	28th day	312.61	Kg/Cm ²	265.00 Kg/Cm ²	19.96	-do-
10		compressive	326.20	Kg/Cm ²			
		strength	314.87	Kg/Cm ²			
		Average	317.89	Kg/Cm ²			
	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 16/05/2019, RCC for floor of Barage from 0-55 m.	28th day	328.46	Kg/Cm ²	265.00 Kg/Cm ²	20.24	-do-
11		compressive	310.34	Kg/Cm ²			
		strength	317.14	Kg/Cm ²			
		Average	318.65	Kg/Cm ²			
	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 16/05/2019, RCC for floor of Barage from 0-55 m.	28th day	321.67	Kg/Cm ²	265.00 Kg/Cm ²	19.96	-do-
12		compressive	317.14	Kg/Cm ²			
		strength	314.87	Kg/Cm ²			
		Average	317.89	Kg/Cm ²			
13	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 16/05/2019, RCC for floor of Barage from 0-55 m.	28th day	310.34	Kg/Cm ²	265.00 Kg/Cm ²	21.10	-do-
		compressive	323.93	Kg/Cm ²			
		strength	328.46	Kg/Cm ²			
		Average	320.91	Kg/Cm ²			
14	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 16/05/2019, RCC for floor of Barage from 0-55 m.	28th day	321.67	Kg/Cm ²	265.00 Kg/Cm ²	20.53	-do-
		compressive	326.20	Kg/Cm ²			
		strength	310.34	Kg/Cm ²			
		Average	319.40	Kg/Cm ²			

^{1.}Copy to: The Assistant Engineer SD I, WD VI, WRD, Bicholim Goa.

^{2.} Copy submitted to:The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa. For kind Information.

^{3.} Copy submitted to:The Executive Engineer ,WDVI,WRD, Bicholim-Goa.

^{4.} QC Lab File. 5. Bill File.