GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD/QC/F.6-2/Cube -T : 7235 To 7248 / Lab / **190**/ 2019 - 20 Dated: 17 / 06 / 2019

Laboratory: Bicholim-Goa / Sub Division V (QC)/WRD/ Bicholim-Goa.

Name of Work: - Construction of Barrage and up gradation of Raw water pumping station at Ganjem on Mhadei River for Augmentation of Raw water for Opa water works Reg. Construction of Barrage, providing and laying 1000 mm dia. D.I. pipe Rising main and Break Pressure Tank at Ganjem in Sattari Taluka.

Ref. to Requisition No.: WRD/WDVI/SD I /F.W.215/2019-20/ 203 Dated :- 14-06-2019

Qty. Recived.: 14 Sets of cube Date of Receipt: - 14/06/2019. Tested on: -14/06/2019 Ref to CPWD: 2002, Vol. I

Sample: PCC 1:1.5:3 Mix O.S No.: 857/AF To 870/AF. Lab. Sample No.: 6130 To 6143. Tested By: - Mr. Anil R. Fadte, J.E.

REPORT PAGE 01 OF 02

SR.NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 17/05/2019, RCC for floor of Barage from 55-88 m.	28th day	308.08	Kg/Cm ²	265.00 Kg/Cm ²	21.10	Represents Qty. 20.00 Cum.
		compressive	323.93	Kg/Cm ²			
		strength	330.73	Kg/Cm ²			
		Average	320.91	Kg/Cm ²			
2	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 17/05/2019, RCC for floor of Barage from 55-88 m.	28th day	328.46	Kg/Cm ²	265.00 Kg/Cm ²	19.39	-do-
		compressive	308.08	Kg/Cm ²			
		strength	312.61	Kg/Cm ²			
		Average	316.38	Kg/Cm ²			
	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 17/05/2019, RCC for floor of Barage from 55-88 m.	28th day	310.34	Kg/Cm ²	265.00 Kg/Cm ²	20.53	-do-
3		compressive	326.20	Kg/Cm ²			
3		strength	321.67	Kg/Cm ²			
		Average	319.40	Kg/Cm ²			
	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 17/05/2019, RCC for floor of Barage from 55-88 m.	28th day	323.93	Kg/Cm ²	265.00 Kg/Cm ²	19.96	-do-
4		compressive	303.55	Kg/Cm ²			
-		strength	326.20	Kg/Cm ²			
		Average	317.89	Kg/Cm ²			
5	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 17/05/2019, RCC for floor of Barage from 55-88 m.	28th day	314.87	Kg/Cm ²	265.00 Kg/Cm ²	20.53	-do-
		compressive	312.61	Kg/Cm ²			
		strength	330.73	Kg/Cm ²			
		Average	319.40	Kg/Cm ²			
6	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 17/05/2019, RCC for floor of Barage from 55-88 m.	28th day	326.20	Kg/Cm ²	265.00 Kg/Cm ²	19.96	-do-
		compressive	319.40	Kg/Cm ²			
		strength	308.08	Kg/Cm ²			
		Average	317.89	Kg/Cm ²			

REPORT PAGE 02 OF 02

SR.NO.	DISCRIPTION OF SAMPLE	TESTED FOR			Max./Min.Value permissable	% above or below	REMARK
7	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 17/05/2019, RCC for floor of Barage from 55-88 m.	28th day	317.14	Kg/Cm ²	265.00 Kg/Cm ²	20.24	Represents Qty. 20.00 Cum.
		compressive	328.46	Kg/Cm ²			
		strength	310.34	Kg/Cm ²			
		Average	318.65	Kg/Cm ²			
8	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 17/05/2019, RCC for floor of Barage from 55-88 m.	28th day	330.73	Kg/Cm ²	265.00 Kg/Cm ²	21.95	-do-
		compressive	323.93	Kg/Cm ²			
		strength	314.87	Kg/Cm ²			
		Average	323.18	Kg/Cm ²			
9	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 17/05/2019, RCC for floor of Barage from 55-88 m.	28th day	328.46	Kg/Cm ²	265.00 Kg/Cm ²	21.38	-do-
		compressive	310.34	Kg/Cm ²			
		strength	326.20	Kg/Cm ²			
		Average	321.67	Kg/Cm ²			
	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 17/05/2019, RCC for floor of Barage from 55-88 m.	28th day	326.20	Kg/Cm ²	265.00 Kg/Cm ²	21.38	-do-
10		compressive	310.34	Kg/Cm ²			
10		strength	328.46	Kg/Cm ²			
		Average	321.67	Kg/Cm ²			
	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 17/05/2019, RCC for floor of Barage from 55-88 m.	28th day	326.20	Kg/Cm ²	265.00 Kg/Cm ²	21.67	-do-
11		compressive	328.46	Kg/Cm ²			
11		strength	312.61	Kg/Cm ²			
		Average	322.42	Kg/Cm ²			
	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 17/05/2019, RCC for floor of Barage from 55-88 m.	28th day	301.28	Kg/Cm ²	265.00 Kg/Cm ²	19.96	-do-
12		compressive	323.93	Kg/Cm ²			
12		strength	328.46	Kg/Cm ²			
		Average	317.89	Kg/Cm ²			
	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 17/05/2019, RCC for floor of Barage from 55-88 m.	28th day	330.73	Kg/Cm ²	265.00 Kg/Cm ²	22.24	-do-
13		compressive	326.20	Kg/Cm ²			
13		strength	314.87	Kg/Cm ²			
		Average	323.93	Kg/Cm ²			
	Reinforced Cement concrete cube of mix 1:1.5:3 , cast on 17/05/2019, RCC for floor of Barage from 55-88 m.	28th day	323.93	Kg/Cm ²	265.00 Kg/Cm ²	20.81	-do-
14		compressive	305.81	Kg/Cm ²			
14		strength	330.73	Kg/Cm ²			
		Average	320.16	Kg/Cm ²			

^{1.}Copy to: The Assistant Engineer SD I, WD VI, WRD, Bicholim Goa.

^{2.} Copy submitted to:The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa. For kind Information.

^{3.} Copy submitted to:The Executive Engineer ,WDVI,WRD, Bicholim-Goa.

^{4.} QC Lab File. 5. Bill File.