

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of retaining wall for the nallah in Sy.No. 242/1 at Senaulim in V.P. Verna in Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	8042						168.89		No. WRD/SD I/ WD II/
	8043	23-05-2021	20-06-2021	Foundation	1.2.4	150 kg/cm2	168.89	168.89	F.Esst/155/2021-22
	8044						168.89		DATED:- 16-06-2021
1.2	8045						164.44		
	8046	23-05-2021	20-06-2021	Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	8047						168.89		
2.1	8048						164.44		
	8049	25-05-2021	22-06-2021	Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	8050						168.89		
2.2	8051						168.89		
	8052	25-05-2021	22-06-2021	Foundation	1.2.4	150 kg/cm2	164.44	167.41	do
	8053						168.89		
3.1	8054						168.89		
	8055	26-05-2021	23-06-2021	Foundation	1.2.4	150 kg/cm2	164.44	167.41	do
	8056						168.89		
3.2	8057						168.89		
	8058	26-05-2021	23-06-2021	Foundation	1.2.4	150 kg/cm2	168.89	168.89	do
	8059						168.89		
4.1	8060						168.89		
	8061	28-05-2021	25-06-2021	Wall/ Bands	1.2.4	150 kg/cm2	164.44	167.41	do
	8062						168.89		
4.2	8063						168.89		
	8064	28-05-2021	25-06-2021	Wall/ Bands	1.2.4	150 kg/cm2	168.89	168.89	do
	8065						168.89		

Sandip Parab
JUNIOR ENGINEER.

Pravin C Parsekar
ASSISTANT ENGINEER