

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to Ganapatiwada Talli in ward No. 05 of V.P. Betqui Candola in Priol Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	4253						106.67		No. WRD/WD XI/ SD IV/
	4254	17-03-2021	24-03-2021	For Base	1.2.4	100 kg/cm ²	106.67	106.67	F.cf/219/2020-21.
	4255						106.67		DATED: 19-03-2021
2	4256						106.67		
	4257	18-03-2021	25-03-2021	For Base	1.2.4	100 kg/cm ²	106.67	108.15	do
	4258						111.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER