

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to Ganapatiwada Talli in ward No. 05 of V.P. Betqui Candola in Priol Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	4259						186.67		No. WRD/WD XI/ SD IV/
	4260	17-03-2021	14-04-2021	For Base	1.2.4	150 kg/cm ²	191.11	189.63	F.cf/219/2020-21.
	4261						191.11		DATED: 19-03-2021
2	4262						186.67		
	4263	18-03-2021	15-04-2021	For Base	1.2.4	150 kg/cm ²	186.67	188.15	do
	4264						191.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER